



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11159-36-3850
State Number
13884

EQUIPMENT INSPECTED

State Number: 13884	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 01/15/1991	Rope Size:
Volts: 208	Complied: 01/15/1991	Entrances: 1
OWNER	OCCUPANT	
ANDERSEN ENERGY, INC.	ANDERSEN PRODUCTS, INC.	
3151 CAROLINE DR.	3202 CAROLINE DR.	
HAW RIVER, NC, 27258	HAW RIVER, NC, 27258	

INSPECTION INFORMATION

Inspection Date 06/08/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: (800) 523-1276

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANDERSEN ENERGY, INC.
3151 CAROLINE DR.
HAW RIVER, NC, 27258