



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-707-7927

Report Number  
**11160-50-0154**  
State Number  
**24950**

EQUIPMENT INSPECTED

State Number: **24950**                      Type of Unit: Passenger                      Floor to Floor: 1 to 3  
Capacity: 3500                              Manuf: THYSSEN KRUPP                      Speed: 125  
Landings: 2                                  Installed: 06/19/2007                      Rope Size: 0  
Volts: 480                                    Complied:                                      Entrances: 1

OWNER    OCCUPANT  
CITY OF CHARLOTTE CATS FACILITIES                      CATS SOUTH BOULEVARD LIGHT RAIL FACILITY  
600 E. 4TH ST                                      3200 S. BLVD  
CHARLOTTE, NC, 28202                              CHARLOTE, NC, 28217

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
06/09/2011	Routine	Re-issued	50 - Offe	MECKLENBURG	60 F

VIOLATIONS

2.2.5.1                                      Put the pit lights in proper working order.  
8.11.3.2.1                                      Perform the annual relief valve test

Items must be corrected by: 07/09/2011

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brent Roland# 704-432-5008

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF CHARLOTTE CATS FACILITIES  
600 E. 4TH ST  
CHARLOTTE, NC, 28202