



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11164-52-3297**  
State Number  
**13063**

EQUIPMENT INSPECTED

State Number: <b>13063</b>	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: SOUTHERN	Speed: 115
Landings: 5	Installed: 05/31/1989	Rope Size: 0
Volts: 208	Complied: 05/31/1989	Entrances: 2

OWNER  
ELK RIVER COUNTRY CLUB  
1000 CLUBHOUSE DRIVE  
BANNER ELK, NC, 28604

OCCUPANT  
ELK RIVERCLUB HOUSE  
235 CLUB HOUSE DRIVE  
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date 06/13/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

2.14.7.4 Protect the car lights from accidental contact.

Items must be corrected by: 07/13/2011

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Elk River 828-896-9773

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELK RIVER COUNTRY CLUB  
1000 CLUBHOUSE DRIVE  
BANNER ELK, NC, 28604