



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11165-17-5931**  
State Number  
**10680**

EQUIPMENT INSPECTED

State Number: <b>10680</b>	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 2500	Manuf: ASHEVILLE	Speed: 150
Landings: 6	Installed: 03/01/1984	Rope Size:
Volts: 208	Complied: 01/12/2007	Entrances: 1
OWNER	OCCUPANT	
AMBICA LLC	HOLIDAY INN ASHEVILLE	
PO BOX 2470	435 SMOKEY PARK HWY	
CANDLER, NC, 28715	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 06/14/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4.9	Clean the elevator car top.
2.26.2.7	Put the pit stop switch in red and label.
8.6.4	Repair door relating idler.
8.6.4	Keep car door from dragging sill.

Items must be corrected by: 07/14/2011

Elevator Name: #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: front desk 828-665-2161

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AMBICA LLC  
PO BOX 2470  
CANDLER, NC, 28715