

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-807-2770

Report Number <b>11167-48-1997</b> State Number <b>22761</b>
-----------------------------------------------------------------------

EQUIPMENT INSPECTED

State Number: <b>22761</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 06/02/2005	Rope Size:
Volts: 208	Complied: 06/02/2005	Entrances: 1
OWNER	OCCUPANT	
HARBORSIDE CONDO'S COA	HARBORSIDE CONDOS @ S.P.	
1861 RAEFORD RD.	600 W WEST STREET	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 06/16/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. ALL FLOORS

Items must be corrected by: 06/26/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JOHN DOSHER

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372  
An invoice will be mailed to: HARBORSIDE CONDO'S COA  
1861 RAEFORD RD.  
SOUTHPORT, NC, 28461