



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11168-17-0990**  
State Number  
**22348**

EQUIPMENT INSPECTED

State Number: <b>22348</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: AEC	Speed: 100
Landings: 2	Installed: 04/30/2004	Rope Size: 0
Volts: 208	Complied: 04/30/2004	Entrances: 1

OWNER

ALAN'S PAWN  
1186 PATTON AVE.  
ASHEVILLE, NC, 28806

OCCUPANT

ALAN'S PAWN  
1186 PATTON AVE.  
ASHEVILLE, NC, 28806

INSPECTION INFORMATION

Inspection Date 06/17/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.10	Perform the annual smoke detector test.

Items must be corrected by: 07/17/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ronald 828-254-8681

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAN'S PAWN  
1186 PATTON AVE.  
ASHEVILLE, NC, 28806