



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11171-48-4523
State Number
14615

EQUIPMENT INSPECTED

State Number: 14615	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 09/17/1992	Rope Size:
Volts: 480	Complied: 10/01/1992	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSOR	
1911 S. CHURCH ST.	NC HWY. 87S	
SMITHFIELD, VA, 23430	TARHEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 06/20/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

8.6.4.8.2	Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
8.6.4.7.1	Clean the elevator pit.
8.6.4.13.1[k]	Properly maintain door closers, where required. MOTOR ROOM DOOR
2.27.1.1.2	Put the in car emergency telephone in proper working order. ALSO COVER DAMAGED

Items must be corrected by: 07/20/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DENNIS PARKS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING
1911 S. CHURCH ST.
SMITHFIELD, VA, 23430