



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11179-17-0441
State Number
6775

EQUIPMENT INSPECTED

State Number: 6775	Type of Unit: Passenger	Floor to Floor: G to 7
Capacity: 2500	Manuf: WESTINGHOUSE	Speed: 350
Landings: 8	Installed: 11/24/1970	Rope Size: 1/2
Volts: 550	Complied: 02/02/1971	Entrances: 1

OWNER

ASHEVILLE BUNCOMBE TECH COLL
340 VICOTRIA RD
ASHEVILLE, NC, 28801

OCCUPANT

ASHEVILLE BUNCOMBE COLL
1459 SANDHILL RD.
CANDLER, NC, 28715

INSPECTION INFORMATION

Inspection Date 06/28/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4	Replace loose door gibs.
Rec	Provide a second stop switch in pit .
8.6.4	Provide light guard on pit light.

Items must be corrected by: 07/28/2011

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eddie 828-254-1921

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COLL
340 VICOTRIA RD
ASHEVILLE, NC, 28801