N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11193-8-5447
State Number
17595

EQUIPMENT INSPECTED

State Number: **17595**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 07/10/1998	Rope Size:
Volts: 480	Complied: 07/16/1998	Entrances: 1

OWNER
SOUTH PIEDMONT COMMUNITY COLLEGE
ATT: ACCTS PAYABLE
POLKTON, NC, 28135

OCCUPANT
SOUTH PIEDMONT COMMUNITY COLLEGE
129 LEDBETTER ST
POLKTON, NC, 28135

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/12/2011	Routine	Re-issued	8 - Burris	ANSON

4

VIOLATIONS

NONE

Elevator Name: MARTIN BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: REP- WILLIAM TRUETT Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SOUTH PIEDMONT COMMUNITY COLLEGE
ATT: ACCTS PAYABLE
POLKTON, NC, 28135