N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11206-48-2486
State Number
19902

EQUIPMENT INSPECTED

State Number: **19902**	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 05/07/2001	Rope Size:
Volts: 208	Complied: 05/15/2001	Entrances: 1

OWNER	OCCUPANT
SEATRAIL CORP0RATION	SEA TRAIL CHAMPIONS BLDG. #34
279 CLUBHOUSE RD	133 AVIAN DR
SUNSET BEACH, NC, 28668	SUNSET BEACH, NC, 28668

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
07/25/2011	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
5.1.21.1	Put the in car alarm bell in working order.

Items must be corrected by: 08/14/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEATRAIL CORP0RATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28668