N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11206-8-2210
State Number
15555

EQUIPMENT INSPECTED

State Number: **15555**
Capacity: 10000
Landings: 4
Volts: 0

Type of Unit: Freight
Manuf: THYSSEN KRUPP
Installed: 12/02/1994
Complied: 12/21/1994

Floor to Floor: 1 to 4
Speed: 75
Rope Size:
Entrances: 1

OWNER
UNIVERSAL FIBER SYSTEMS LLC
PO BOX 436
ANSONVILLE, NC, 28007

OCCUPANT
PREMIERE FIBERS INC
HWY 52 N
ANSONVILLE, NC, 28007

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/25/2011	Routine	Re-issued	8 - Burris	ANSON

4

VIOLATIONS

8.11 PERFORM ANNUAL PRESURE RELIEF VALVE TEST
8.6 CLEAN ELEVATOR CAR TOP

Elevator Name: BIG FREIGHT ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: REP- SURESH SUNDARAMOORTHY Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
UNIVERSAL FIBER SYSTEMS LLC
PO BOX 436
ANSONVILLE, NC, 28007