N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11207-48-5574
State Number
15684

EQUIPMENT INSPECTED

State Number: **15684**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 10/30/1995
Complied: 10/30/1995

Floor to Floor: G to 2
Speed: 125
Rope Size:
Entrances: 1

OWNER
CASWLL PARTNERSHIP
OCEAN GREENS LANE
CASWELL BEACH, NC, 28465

OCCUPANT
OCEAN GREENS BLDG #2
55-58 FOX FIRE LN.
CASWELL BEACH, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/26/2011	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 08/15/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CASWLL PARTNERSHIP
OCEAN GREENS LANE
CASWELL BEACH, NC, 28465