



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11210-8-1211
State Number
14371

EQUIPMENT INSPECTED

State Number: 14371	Type of Unit: Dumbwaiter	Floor to Floor: E to M
Capacity: 500	Manuf: MATOT	Speed: 50
Landings: 2	Installed: 06/26/1992	Rope Size: 1/4
Volts: 480	Complied: 07/02/1992	Entrances: 1
OWNER	OCCUPANT	
RANDOLPH HOSPITAL	RANDOLPH HOSPITAL	
PO BOX 1048	364 WHITE OAK ST	
ASHEBORO, NC, 27204	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 07/29/2011	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------------	----------------------------------	-------------------------	--------------------

76

VIOLATIONS

Elevator Name: 9

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH HOSPITAL
PO BOX 1048
ASHEBORO, NC, 27204