



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11213-7-4797**  
State Number  
**27760**

EQUIPMENT INSPECTED

State Number: <b>27760</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 08/01/2011	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
THREE FORKS BAPTIST CHURCH	THREE FORKS BAPTIST CHURCH	
4865 THREE FORKS CHURCH RD	4865 THREE FORKS CHURCH RD	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 08/01/2011	Type Inspection New	Certificate Status Not Issued	Inspector 7 - Hoffman	County ALEXANDER
-------------------------------	------------------------	----------------------------------	--------------------------	---------------------

2

VIOLATIONS

NCR REMOVE SUMP PUMP CONTROLLER FROM THE PIT

Items must be corrected by: 08/11/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: otis elevator co.

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THREE FORKS BAPTIST CHURCH  
4865 THREE FORKS CHURCH RD  
TAYLORSVILLE, NC, 28681