



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11220-7-0497
State Number
15672

EQUIPMENT INSPECTED

State Number: 15672	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: KONE	Speed: 80
Landings: 2	Installed: 09/26/1994	Rope Size:
Volts: 480	Complied: 09/28/1994	Entrances: 1
OWNER	OCCUPANT	
MARTIN MARIETTA	MARTIN MARIETTA	
114 INDUSTRIAL PARK DR.	114 INDUSTRIAL PARK DR.	
SPARTA, NC, 28675	SPARTA, NC, 28675	

INSPECTION INFORMATION

Inspection Date 08/08/2011	Type Inspection Removed	Certificate Status Not Issued	Inspector 7 - Hoffman	County ALLEGHANY
-------------------------------	----------------------------	----------------------------------	--------------------------	---------------------

3

VIOLATIONS

BUILDING CLOSED

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: NCDOL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MARTIN MARIETTA
114 INDUSTRIAL PARK DR.
SPARTA, NC, 28675