



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11228-16-1075
State Number
25683

EQUIPMENT INSPECTED

State Number: 25683	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 4	Installed: 07/31/2008	Rope Size: 0
Volts: 208	Complied: 07/31/2008	Entrances: 1

OWNER

MOSS LANDING OWNERS ASSOC
PO BOX 1178
EDENTON, NC, 27932

OCCUPANT

MOSS LANDING
401 MOSS WAY
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 08/16/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.11.3.2.1 Perform the annual relief valve test

Items must be corrected by: 09/15/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stan Friedman

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MOSS LANDING OWNERS ASSOC
PO BOX 1178
EDENTON, NC, 27932