N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11251-48-2466
State Number
21953

EQUIPMENT INSPECTED

State Number: **21953**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 06/17/2004
Complied: 06/24/2004

Floor to Floor: 1 to 2
Speed: 100
Rope Size: .
Entrances: 1

OWNER
NANCY LEWIS
100 STATION HOUSEWAY
BALDHEAD ISLAND, NC, 28461

OCCUPANT
SHOALS CLUB PHASE I
100 STATION HOUSEWAY
BALDHEAD ISLAND, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
09/08/2011	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 10/08/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: RICHARD SCEARCE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
NANCY LEWIS
100 STATION HOUSEWAY
BALDHEAD ISLAND, NC, 28461