N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11258-24-3554
State Number
23181

EQUIPMENT INSPECTED

State Number: **23181**	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 09/21/2005	Rope Size: 3/8"
Volts: 208	Complied: 09/23/2005	Entrances: 1

OWNER
49 BROADWAY ARTS CONDOMINIUM ASSOC.
12 1/2 WALL STREET / SUITE "D"
ASHEVILLE, NC, 28801

OCCUPANT
49 BROADWAY ARTS CONDOMINIUMS
49 BROADWAY AVE.
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
09/15/2011	Routine	Re-issued	24 - Moore	BUNCOMBE	11 B

VIOLATIONS

8.11.2.3 Perform a 5 year full load safety test. Last date 9/05

Items must be corrected by: 10/15/2011 Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: John Ball / 828-252-9255 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
49 BROADWAY ARTS CONDOMINIUM ASSOC.
12 1/2 WALL STREET / SUITE "D"
ASHEVILLE, NC, 28801