



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11262-48-1119
State Number
8102

EQUIPMENT INSPECTED

State Number: 8102	Type of Unit: Freight	Floor to Floor: 1 to 4
Capacity: 16000	Manuf: SOUTHEASTERN	Speed: 75
Landings: 4	Installed: 10/22/1975	Rope Size: 5/8
Volts: 480	Complied: 10/16/2001	Entrances: 1
OWNER	OCCUPANT	
ARCHER DANIELS MIDLAND	ARCHER DANIELS MIDLAND	
MOORE ST EXT - PO BOX 10640	EAST MOORE ST EXT - BLDG. 105	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 09/19/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 10/19/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JIM REIBERT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARCHER DANIELS MIDLAND
MOORE ST EXT - PO BOX 10640
SOUTHPORT, NC, 28461