



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11262-48-3836**  
State Number  
**15105**

#### EQUIPMENT INSPECTED

|                            |                                |                        |
|----------------------------|--------------------------------|------------------------|
| State Number: <b>15105</b> | Type of Unit: Freight          | Floor to Floor: 1 to 5 |
| Capacity: 5000             | Manuf: VIOLA                   | Speed: 100             |
| Landings: 5                | Installed: 03/22/1994          | Rope Size: 5/8         |
| Volts: 480                 | Complied: 11/03/2005           | Entrances: 1           |
| OWNER                      | OCCUPANT                       |                        |
| ARCHER DANIELS MIDLAND CO  | ARCHER DANIELS MIDLAND COMPANY |                        |
| P O BOX 10640              | EAST MOORE ST EXT. - BLDG. 205 |                        |
| SOUTHPORT, NC, 28461       | SOUTHPORT, NC, 28461           |                        |

#### INSPECTION INFORMATION

|                               |                            |                                 |                          |                     |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date<br>09/19/2011 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>48 - Martin | County<br>BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

#### VIOLATIONS

- 8.6.4.13.1 All landing and car-door or gate mechanical and electrical components shall be maintained to ensure safe and proper operation. CAR DOOR REOPENING.
- 5.1.21.1 Put the in car alarm bell in working order.
- 8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 10/19/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JIM REIBERT

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARCHER DANIELS MIDLAND CO  
P O BOX 10640  
SOUTHPORT, NC, 28461