



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11263-48-2937**  
State Number  
**23453**

EQUIPMENT INSPECTED

State Number: <b>23453</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3000	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 12/05/2005	Rope Size: 0
Volts: 208	Complied: 12/05/2005	Entrances: 1
OWNER	OCCUPANT	
COMMUNITY ASSOCIATION MANAGEMENT	COLONY II BLDG 8	
PO BOX 8126	908 RESORT CIRCLE	
OCEAN ISLE BEACH, NC, 28469	SUNSET BEACH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 09/20/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MANAGEMENT  
PO BOX 8126  
OCEAN ISLE BEACH, NC, 28469