



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11269-36-4982
State Number
25341

EQUIPMENT INSPECTED

State Number: 25341	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 04/15/2008	Rope Size:
Volts: 208	Complied:	Entrances: 1

OWNER

ETHAN POINTE APARTMENTS
2978 ETHAN POINTE DRIVE
BURLINGTON, NC, 27215

OCCUPANT

ETHAN POINTE APARTMENTS
1176 KIRKPATRICK ROAD
BHRLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 09/26/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

None found

Elevator Name: BUILDING # 6

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KAREN VEZINA 336-584-3337

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ETHAN POINTE APARTMENTS
2978 ETHAN POINTE DRIVE
BURLINGTON, NC, 27215