

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-807-2770

Report Number  
**11277-8-2815**  
State Number  
**17858**

EQUIPMENT INSPECTED

State Number: <b>17858</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 04/06/1999	Rope Size:
Volts: 208	Complied: 04/06/1999	Entrances: 1
OWNER	OCCUPANT	
EAST COAST HOSPITALITY	HOLIDAY INN EXPRESS	
719 W 15TH STREET STE 11	1113 E DIXIE DRIVE	
WASHINGTON, NC, 27889	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/04/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH	76
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	----

VIOLATIONS

NEC REMOVE EXPOSED WIRE IN ELEVATOR MACHINE  
NEC REMOVE ALL OUTSIDE CORDS FROM ELEVAQTOR MACHINE ROOM

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: REP- KATHERINE CUMMINGS

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

EAST COAST HOSPITALITY  
719 W 15TH STREET STE 11  
WASHINGTON, NC, 27889