



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11291-48-2239
State Number
24755

EQUIPMENT INSPECTED

State Number: **24755**

Capacity: 2500

Landings: 2

Volts: 208

OWNER

EXUM FAMILY 497,LLC

P O BOX 1967

WILMINGTON, NC, 28402

Type of Unit: Passenger

Manuf: OTIS

Installed: 05/31/2007

Complied: 05/31/2007

OCCUPANT

WATERFORD TOWN HALL BLDG

497 OLD WATERFORD WAY

LELAND, NC, 28451

Floor to Floor: to

Speed: 100

Rope Size:

Entrances: 1

INSPECTION INFORMATION

Inspection Date
10/18/2011

Type Inspection
Compliance

Certificate Status
Prev Issued

Inspector
48 - Martin

County
BRUNSWICK

10

VIOLATIONS

n/a No violations found

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LISA BRITT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

EXUM FAMILY 497,LLC
P O BOX 1967
WILMINGTON, NC, 28402