N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11291-48-5588
State Number
19913

EQUIPMENT INSPECTED

State Number: **19913**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 06/29/2001
Complied: 07/03/2001

Floor to Floor: 1 to 2
Speed: 100
Rope Size: .
Entrances: 2

OWNER
NCDOT
25 OLD RIVER RD
LELAND, NC, 28451

OCCUPANT
NCDOT WILMINGTON BRIDGE MAINT FAC
25 OLD RIVER RD
LELAND, NC, 28451

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
10/18/2011	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

n/a No violations found

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: AL

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
NCDOT
25 OLD RIVER RD
LELAND, NC, 28451