



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11291-8-2466
State Number
16142

EQUIPMENT INSPECTED

State Number: 16142	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 8000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 4	Installed: 03/28/1996	Rope Size: 5/8
Volts: 480	Complied: 04/10/1996	Entrances: 1

OWNER

STAR PET
801 PINEVIEW RD
ASHEBORO, NC, 27203

OCCUPANT

STAR PET
801 PINEVIEW RD
ASHEBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date 10/18/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6 PROVIDE PROPER C/W RUN BY (SHORTEN CABLES)

Items must be corrected by: 11/17/2011

Elevator Name: CP BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- JESSE CALLOWAY

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

STAR PET
801 PINEVIEW RD
ASHEBORO, NC, 27203