N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11292-48-0528
State Number
14064

EQUIPMENT INSPECTED

State Number: **14064**
Capacity: 2000
Landings: 2
Volts: 460

Type of Unit: Passenger
Manuf: KONE
Installed: 08/15/1990
Complied: 09/07/1990

Floor to Floor: 1 to 2
Speed: 80
Rope Size:
Entrances: 1

OWNER
BRUNSWICK COMMUNITY COLLEGE
PO BOX 30
SUPPLY, NC, 28462

OCCUPANT
BRUNSWICK COMMUNITY COLLEGE
2050 ENTERPRISE DRIVE
LELAND, NC, 28451

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
10/19/2011	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 10/29/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: LAURIE LEIGHTON

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BRUNSWICK COMMUNITY COLLEGE
PO BOX 30
SUPPLY, NC, 28462