



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11293-48-2567
State Number
16310

EQUIPMENT INSPECTED

State Number: 16310	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/21/1996	Rope Size:
Volts: 208	Complied: 10/03/1996	Entrances: 1
OWNER	OCCUPANT	
OCEAN ISLE BEACH TOWN HALL	OCEAN ISLE BEACH TOWN HALL	
3 W THIRD ST	3 W THIRD ST	
OCEAN ISLE, NC, 27469	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 10/20/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[k] Properly maintain door closers, where required. REPAIR MOTOR ROOM DOOR CLOSER.

Items must be corrected by: 11/09/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LARRY [MGMT.]

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN ISLE BEACH TOWN HALL
3 W THIRD ST
OCEAN ISLE, NC, 27469