N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11297-48-0255
State Number
24166

EQUIPMENT INSPECTED

State Number: **24166**
Capacity: 2500
Landings: 5
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER, HYD
Installed: 02/28/2007
Complied: 03/01/2007

Floor to Floor: 1 to 5
Speed: 125
Rope Size: 0
Entrances: 1

OWNER
CAMS
1630 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403

OCCUPANT
THE PRESERVE BLDG #3 - CAR #2
3100 MARSH GROVE LANE
OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
10/24/2011	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced.
2.2.2.4	Install the cover on the sump pump.
8.6.4.7.4	Remove the water from the pit floor.

Items must be corrected by: 11/13/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAMS
1630 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403