



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11297-8-3716**  
State Number  
**480**

EQUIPMENT INSPECTED

State Number: <b>480</b>	Type of Unit: Freight	Floor to Floor: B to 3
Capacity: 2000	Manuf: OTIS	Speed: 75
Landings: 5	Installed: 01/11/1946	Rope Size: 1/2
Volts: 220	Complied: 01/11/1946	Entrances: 2

OWNER  
ACME MCCRARY CORP  
BOX 1287  
ASHEBORO, NC, 27204-1287

OCCUPANT  
ACME MCCRARY CORP  
159 NORTH ST  
ASHEBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date 10/24/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

- 8.6 REPLACE BOTH HOISTWAY CATE CABLES 1ST FLOOR BROKEN LAY
- 8.6 PROVIDE PROPER C/W RUNBY (SHORTEN ROPES)

Items must be corrected by: 11/23/2011

Elevator Name: Red Gate

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: MARILYN VAN HORN

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ACME MCCRARY CORP  
BOX 1287  
ASHEBORO, NC, 27204-1287