



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11298-24-4836
State Number
25983

EQUIPMENT INSPECTED

State Number: 25983	Type of Unit: Passenger	Floor to Floor: 1 to 11
Capacity: 3500	Manuf: SCHINDLER	Speed: 350
Landings: 11	Installed: 11/04/2008	Rope Size: 11mm
Volts: 480	Complied:	Entrances: 1
OWNER		OCCUPANT
60 NORTH MARKET ST. CONDO ASSOCIATION		60 NORTH MARKET STREET
C/O IPM CORP/ ATTN:STEPHANIE CLARK		60 N MARKET STREET
ARDEN, NC, 28704-0580		ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 10/25/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 8.11.2.2.2 Perform the annual no load safety test. Last date 8/10
- 8.6.4.11.1 Provide proper car and counterweight runby that is not reduced below that required at the time of installation or alteration, and the final terminal-stopping device is still operational.

Items must be corrected by: 11/24/2011

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stephanie Clark / 828-650-6875

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

60 NORTH MARKET ST. CONDO ASSOCIATION
C/O IPM CORP/ ATTN:STEPHANIE CLARK
ARDEN, NC, 28704-0580