



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11298-48-5520
State Number
26742

EQUIPMENT INSPECTED

State Number: 26742	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/17/2009	Rope Size:
Volts: 208	Complied: 08/17/2009	Entrances: 1

OWNER

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462

OCCUPANT

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date 10/25/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.5.5.2	Empty the drain bucket in the pit.
8.6.4.7.4	Remove the oil from the pit floor.

Items must be corrected by: 11/04/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MEGEN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462