



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11299-8-3531
State Number
25634

EQUIPMENT INSPECTED

State Number: 25634	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 20000	Manuf: OTIS	Speed: 50
Landings: 2	Installed: 12/22/2008	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
MALT O MEAL	MALT O MEAL	
2525 BANK STREET	2525 BANK STREET	
ASHBORO, NC, 27203	ASHBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/26/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.11 PERFORM ANNUAL PRESSURE RELIEF VALVE TEST

Items must be corrected by: 11/25/2011

Elevator Name: RTE BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- AL SPENCER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MALT O MEAL
2525 BANK STREET
ASHBORO, NC, 27203