

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-807-2770

Report Number <b>11308-48-0172</b> State Number <b>25220</b>
---

EQUIPMENT INSPECTED

State Number: <b>25220</b>	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 5	Installed: 05/29/2008	Rope Size:
Volts: 208	Complied: 05/29/2008	Entrances: 1

OWNER

REGENCY CONDO HOA CAMS INC.  
1630 MILITARY CUTOFF RD. STE 108  
WILMINGTON, NC, 28403

OCCUPANT

REGENCY CONDOS BLDG 2  
915 SHORELINE DR. W  
SUNSET BEACH, NC, 28467

INSPECTION INFORMATION

Inspection Date 11/04/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 11/24/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

REGENCY CONDO HOA CAMS INC.  
1630 MILITARY CUTOFF RD. STE 108  
WILMINGTON, NC, 28403