



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11312-48-1982
State Number
23562

EQUIPMENT INSPECTED

State Number: 23562	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 05/24/2006	Rope Size: 0
Volts: 208	Complied: 10/12/2006	Entrances: 1
OWNER	OCCUPANT	
SEA COAST REALTY	LIVE OAK BLDG SEA COAST REALTY	
4911 LONGBEACH ROAD	4911 LONGBEACH ROAD	
SOUTH PORT, NC, 28461	SOUTH PORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 11/08/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 12/08/2011

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: VICKI

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA COAST REALTY
4911 LONGBEACH ROAD
SOUTH PORT, NC, 28461