



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11319-48-4619
State Number
22704

EQUIPMENT INSPECTED

State Number: 22704	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 07/06/2005	Rope Size:
Volts: 208	Complied: 07/21/2005	Entrances: 1

OWNER
BRUNSWICK HARBOR, INC.
222 E MEDOW RD
EDEN, NC, 27288

OCCUPANT
ST JAMES PLAN / MARINA
2571 ST. JAMES DR.
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date 11/15/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.27.3.1 Put the Phase I fire service feature in proper working order. IN MOTOR ROOM - SECURE COVERS ON FIRE RECALL RELAYS
- 2.7.5.1 Put the machine room lights in working order.
- 2.27.3.1 Put the Phase I fire service feature in proper working order. NO FIRE HAT LIGHT AT LOBBY

Items must be corrected by: 12/05/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JON HELMS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK HARBOR, INC.
222 E MEDOW RD
EDEN, NC, 27288