N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**11320-48-2371**
State Number
**21756**

## EQUIPMENT INSPECTED

State Number: **21756**
Capacity: 3500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 08/18/2003
Complied: 08/22/2003

Floor to Floor: 1 to 2
Speed: 125
Rope Size: 0
Entrances: 1

OWNER
HIGHEST PRAISE WORSHIP CTR
19 RED BUG ROAD
SHALLOTTE, NC, 28470

OCCUPANT
HIGHEST PRAISE WORSHIP CTR
19 RED BUG ROAD
SHALLOTTE, NC, 28470

## INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County |
|---|---|---|---|---|
| 11/16/2011 | Routine | Re-issued | 48 - Martin | BRUNSWICK |

10

## VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

8.6.4.13.1[k] Properly maintain door closers, where required. MOTOR ROOM DOOR TO CLOSE AND LOCK ON ITS OWN.

Items must be corrected by: 12/06/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DIANE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
HIGHEST PRAISE WORSHIP CTR
19 RED BUG ROAD
SHALLOTTE, NC, 28470