



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11320-7-0254
State Number
26921

EQUIPMENT INSPECTED

State Number: 26921	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 100
Landings: 3	Installed: 05/14/2009	Rope Size:
Volts: 208	Complied: 05/14/2009	Entrances: 2
OWNER	OCCUPANT	
COUNTY OF ASHE	ASHE COUNTY PUBLIC LIBRARY	
150 GOVERNMENT CIRCLE	148 LIBRARY DRIVE	
W JEFFERSON, NC, 28694	WEST JEFFERSON, NC, 28694	

INSPECTION INFORMATION

Inspection Date 11/16/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ANGIE EGGARS 336-846-5508

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COUNTY OF ASHE
150 GOVERNMENT CIRCLE
W JEFFERSON, NC, 28694