



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11320-7-1930
State Number
20110

EQUIPMENT INSPECTED

State Number: 20110	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 04/17/2001	Rope Size:
Volts: 208	Complied: 04/17/2001	Entrances: 1
OWNER	OCCUPANT	
REEVES LAW FIRM	REEVES LAW FIRM	
PO DRAWER 67	306 E MAIN ST	
WEST JEFFERSON, NC, 28694	WEST JEFFERSON, NC, 28694	

INSPECTION INFORMATION

Inspection Date 11/16/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REEVES LAW FIRM 336-246-7172

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

REEVES LAW FIRM
PO DRAWER 67
WEST JEFFERSON, NC, 28694