N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11320-7-2497
State Number
4320

EQUIPMENT INSPECTED

State Number: **4320**
Capacity: 1900
Landings: 3
Volts: 220

Type of Unit: Passenger
Manuf: SOUTHERN
Installed: 02/27/1962
Complied: 04/12/2000

Floor to Floor: 1 to 3
Speed: 50
Rope Size:
Entrances: 1

OWNER
JACK BARR
201 MEADOW RIDGE DR.
JEFFERSON, NC, 28640

OCCUPANT
QUIET COUNTRY AMISH FURN.
109 E MAIN ST
WEST JEFFERSON, NC, 28694

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/16/2011	Routine	Re-issued	7 - Hoffman	ASHE

5

VIOLATIONS

2.27.1	PROVIDE OPERATION OF THE ALARM BELL
8.6	INSTALL BULB IN CAR LIGHT

Items must be corrected by: 12/16/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JACK BARR 336-246-3135 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
JACK BARR
201 MEADOW RIDGE DR.
JEFFERSON, NC, 28640