



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11322-48-4137**  
State Number  
**H1522**

#### EQUIPMENT INSPECTED

State Number: <b>H1522</b>	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: THYSSEN KRUPP	Speed: 12
Landings: 2	Installed: 09/01/2004	Rope Size:
Volts: 115	Complied: 09/01/2004	Entrances: 2
OWNER	OCCUPANT	
COUNTY OF BRUNSWICK	BRUNSWICK COUNTY LIBRARY	
PO BOX 249	1040 CALABASH RD.	
BOLIVIA, NC, 28422	CALABASH, NC, 28467	

#### INSPECTION INFORMATION

Inspection Date 11/18/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

8.6.4.13.1[k] Properly maintain door closers, where required. REPAIR LOBBY DOOR TO CLOSE ON ITS OWN,

Items must be corrected by: 12/18/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CHRISTI IFFERGAN

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COUNTY OF BRUNSWICK  
PO BOX 249  
BOLIVIA, NC, 28422