



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11332-36-5687
State Number
14805

EQUIPMENT INSPECTED

State Number: 14805	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 01/08/1993	Rope Size:
Volts: 200	Complied: 01/11/1993	Entrances: 1
OWNER	OCCUPANT	
TWIN LAKES CENTER	TWIN LAKES CENTER	
100 WADE COBLE DR	100 WADE COBLE DR	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 11/28/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: sue 524 9467

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215