



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11353-16-3592
State Number
6859

EQUIPMENT INSPECTED

State Number: 6859	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1300	Manuf: WESTBROOK	Speed: 100
Landings: 3	Installed: 06/15/1972	Rope Size: 0
Volts: 220	Complied: 07/25/1972	Entrances: 1

OWNER
BEAUFORT CO COURTHOUSE
123 W 3RD ST
WASHINGTON, NC, 27889

OCCUPANT
BEAUFORT CO COURT HOUSE
112 W SECOND ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 12/19/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.6.4.7.4 Remove the water from the pit floor.

Items must be corrected by: 01/18/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Annette Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BEAUFORT CO COURTHOUSE
123 W 3RD ST
WASHINGTON, NC, 27889