



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11353-54-3789
State Number
19839

EQUIPMENT INSPECTED

State Number: 19839	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 03/07/2001	Rope Size:
Volts: 208	Complied: 03/07/2001	Entrances: 1
OWNER	OCCUPANT	
MT OLIVE BAPTIST CHURCH	MT OLIVE BAPTIST CHURCH	
102 MT OLIVE RD	102 MT OLIVE RD	
LEWISTON, NC, 27849	LEWISTON, NC, 27849	

INSPECTION INFORMATION

Inspection Date 12/19/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 01/18/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Diane Kimbroe 252-348-2644

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MT OLIVE BAPTIST CHURCH
102 MT OLIVE RD
LEWISTON, NC, 27849