



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11356-54-1990
State Number
1592

EQUIPMENT INSPECTED

State Number: 1592	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 01/18/1952	Rope Size: 1/2
Volts: 208	Complied: 01/18/1952	Entrances: 1
OWNER	OCCUPANT	
REHAB BUILDERS INC	CASHIE APARTMENTS FOR THE ELDERLY	
BERTIE MEM LIMITED PARTNERSHIP	401 STERLINGWORTH DR	
WINSTON SALEM, NC, 27101	WINDSOR, NC, 27983	

INSPECTION INFORMATION

Inspection Date 12/22/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.1.1	Provide the machine room keys on the premises.
8.6.4.7.1	Clean the elevator pit.
2.14.7.1.3	Put the in car emergency light in working order.
2.27.7.1	Provide Phase I fire service instructions at the recall landing.
8.6.1.4.1[a]	Properly document maintenance records

Items must be corrected by: 01/21/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JAMES WINSTON

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

REHAB BUILDERS INC
BERTIE MEM LIMITED PARTNERSHIP
WINSTON SALEM, NC, 27101