



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-707-7927

Report Number  
**12003-46-1943**  
State Number  
**5938**

EQUIPMENT INSPECTED

State Number: **5938**                      Type of Unit: Passenger                      Floor to Floor: 1 to 6  
Capacity: 2000                              Manuf: SCHINDLER                              Speed: 300  
Landings: 6                                      Installed: 03/27/1968                              Rope Size: 1/2  
Volts: 208                                        Complied: 04/08/1968                              Entrances: 1

OWNER  
ANTHONY ALLEN PROP. MGR.  
PO BOX 10810  
RALEIGH, NC, 27605

OCCUPANT  
FIRST RALEIGH TELEX  
234 FAYETTEVILLE ST  
RALEIGH, NC, 27601

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
12/30/2011	Routine	Re-issued	46 - Jones	WAKE	92 D

VIOLATIONS

- 8.11.2.3 Perform a 5 year full load safety test
- 5.1.21.1 Put the in car alarm bell in working order. (final notice)

Items must be corrected by: 02/02/2012

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: A.A.P.

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANTHONY ALLEN PROP. MGR.  
PO BOX 10810  
RALEIGH, NC, 27605