



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12019-36-5893
State Number
24655

EQUIPMENT INSPECTED

State Number: 24655	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 04/19/2007	Rope Size: 0
Volts: 208	Complied: 04/19/2007	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON ACADEMIC VILLAGE PAVILION	
803 HAGGARD AVENUE	360 ANTIOCH RD	
ELON, NC, 27244	ELON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 01/19/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

None Found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob Willis 336.278.2000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244