



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12020-48-1442
State Number
13918

EQUIPMENT INSPECTED

State Number: 13918	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: EASTERN	Speed: 100
Landings: 2	Installed: 04/19/1990	Rope Size:
Volts: 240	Complied: 04/27/1990	Entrances: 1
OWNER	OCCUPANT	
BRANTLEY PROPERTIES INC	WOODCR0FT APARTMENT	
209 MERCER HILL RD	209 MERCER MILL RD	
ELIZABETHTOWN, NC, 28327	ELIZABETHTOWN, NC, 27893	

INSPECTION INFORMATION

Inspection Date 01/20/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complianace with current codes.

Violations pointed out to: JUNIE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRANTLEY PROPERTIES INC
209 MERCER HILL RD
ELIZABETHTOWN, NC, 28327