



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12026-7-403
State Number
13037

EQUIPMENT INSPECTED

State Number: 13037	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 05/16/1989	Rope Size:
Volts: 240	Complied: 05/25/1989	Entrances: 1

OWNER

A B TECHNICAL COLLEGE IND ED BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801

OCCUPANT

A B TECHNICAL COLLEGE/DOGWOOD
340 VICTORIA RD
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 01/26/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

ncbc Provide a machine room sign.

Items must be corrected by: 02/25/2012

Elevator Name: dogwood

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty Rice 828-254-1921

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

A B TECHNICAL COLLEGE IND ED BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801