



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12026-7-5134
State Number
16690

EQUIPMENT INSPECTED

State Number: 16690	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: AEC	Speed: 100
Landings: 3	Installed: 06/24/1997	Rope Size:
Volts: 208	Complied: 06/24/1997	Entrances: 1
OWNER	OCCUPANT	
AB TECHNICAL COMMUNITY COLLEGE	AB TECHNICAL/HEMLOCK	
340 VICTORIA ROAD	340 VICTORIA ROAD	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 01/26/2012	Type Inspection Removed	Certificate Status Not Issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	----------------------------------	-------------------------	--------------------	------

VIOLATIONS

note Building closed due to lead poisoning.

Items must be corrected by: 01/26/2012

Elevator Name: hemlock

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty Rice 828-254-1921

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECHNICAL COMMUNITY COLLEGE
340 VICTORIA ROAD
ASHEVILLE, NC, 28801